


STANDARD FRAME AND COVERS
 EAST JORDAN IRON WORKS #V-1384
 US FOUNDRY #USF-668, KL

WATERPROOF FRAME AND COVER
 US FOUNDRY #USF-668, KL-BWTL
 OR APPROVED EAST JORDAN IRON WORKS BOLT-DOWN

FLAT SLAB FRAME AND COVER
 US FOUNDRY #USF-1261, KL
 EAST JORDAN IRON WORKS #V-1384-4



COVER TO HAVE A SINGLE, 1"
 DIAMETER VENT HOLE, UNLESS
 BOLT-DOWN COVER IS
 SPECIFIED, IN WHICH CASE,
 THE GASKET SHALL PROVIDE
 POSITIVE SEAL AT BOLT HOLES.

FRAME AND COVER SHALL
 BE CERTIFIED FOR A
 MINIMUM OF AASHTO
 H-20 LOADING



PROVIDE 2 (NON-PENETRATING)
 PICK HOLES

"GREER CPW" SHALL BE CAST
 ON THE COVER
 (SEE DETAIL THIS SHEET)



GREER COMMISSION OF PUBLIC WORKS

STANDARD MANHOLE FRAME & COVER DETAIL

APPROVED BY:		DATE:	DRAWING NO.
--		FEBRUARY 2021	WW-4
SCALE:		REVISED:	
NTS		--	