



NOTES:

- 1) OPEN CUT INSTALLATIONS WILL REQUIRE INSULATED 12 GAUGE COPPER WIRE.
- 2) TRENCHLESS INSTALLATIONS WILL REQUIRE INSULATED 10 GAUGE STAINLESS STEEL WIRE.
- 3) CONTRACTOR SHALL INSTALL DUMMY VALVE BOXES AT INTERVALS NO GREATER THAN 500 FEET, INCLUDING ONE AT THE PUMP STATION AND ONE AT THE DISCHARGE POINT.
- 4) REFER TO BEDDING DETAIL FOR ADDITIONAL INFORMATION.

GREER COMMISSION OF PUBLIC WORKS FORCE MAIN TRACER WIRE DETAIL			
APPROVED BY:	--	DATE:	DRAWING NO.
SCALE:	NTS	FEBRUARY 2021	WW-24
		REVISED:	--