


LOCAL SUPPLIERS OF METER BOXES / METER SETTERS:

- |                                   |                |
|-----------------------------------|----------------|
| A. CONSOLIDATED PIPE & SUPPLY CO. | (864) 964-9370 |
| B. CORE & MAIN                    | (864) 968-0076 |
| C. FERGUSON WATERWORKS            | (864) 716-0955 |
| D. FORTILINE WATERWORKS           | (864) 299-0755 |

- 5/8" METER: NDS MODEL D1200-DISB WITH SOLID PLASTIC COVER
- 1" METER: CARSON MODEL 1324 (15" DEPTH) WITH CAST IRON READER DOOR



NOTES:

1. ALL EXCAVATION BY PLUMBER/CONTRACTOR.
2. APPROXIMATE SIZE OF HOLE WHERE TAP IS MADE IS 5 FT X 5 FT (6 IN BEHIND AND UNDER MAIN). HOLE TO BE WIDER AND SHORED WHEN MAIN IS DEEPER THAN 5 FT.
3. FOR 5/8" METER, PLUMBER WILL PROVIDE ALL MATERIAL (EXCEPT FOR CORPORATION STOP), INCLUDING COPPER TUBING, METER BOX, METER SETTER, AND CURB STOP AND INSTALL SERVICE(S) UNDER GREER CPW SUPERVISION. FOR 1" METER, ALL MATERIAL (EXCEPT FOR COPPER TUBING AND CURB STOP) SUPPLIED BY GREER CPW.
4. SERVICE LINE MUST HAVE 36" COVER (MINIMUM) UNDER ROADSIDE DITCH.
5. SERVICE LINE SHALL NOT BE PLACED UNDER DRIVEWAY.
6. METER BOXES SHALL BE INSTALLED PERPENDICULAR TO THE PROPERTY LINE, AS SHOWN HEREIN.
7. PLUMBER/CONTRACTOR SHALL PROVIDE A SLEEVE OR CONDUIT (PVC - 2" SCHEDULE 40 OR 2" SDR 21) FOR LONG SIDE SERVICE LINE. SLEEVE TO EXTEND BEYOND BACK OF CURB, ASPHALT, OR SIDEWALK.
8. PLUMBER SHALL CALL GREER CPW (864.848.5500) WHEN READY FOR METER TO BE INSTALLED OR FOR ASSISTANCE IF UNUSUAL CONDITIONS EXIST.
9. OUTLET PIPING CONSISTS OF 2 FT OF OUTLET SERVICE PIPE AND GATE VALVE WITH ACCESS BOX TO BE PROVIDED AND INSTALLED BY PLUMBER PRIOR TO GREER CPW ARRIVAL TO SITE.
10. USE MUELLER CO. (MODEL H-15428N) OR DRESSER (STYLE #88) BRASS COMPRESSION FITTINGS FOR COPPER TUBING.

METER SETTER

FORD METER BOX CO.

- 5/8" METER: MODEL VBHH72-7W-11-33-NL
- 1" METER: MODEL VBHH74-10W-11-44-NL

GREER COMMISSION OF PUBLIC WORKS  
TYPICAL RESIDENTIAL WATER SERVICE DETAIL

APPROVED BY:		DATE:	DRAWING NO.
--		FEBRUARY 2021	
SCALE:		REVISED:	
NTS		--	W-7